Modular 2/4-Channel PID Temperature **Controllers with Screwless Connector** 

# **TM Series** INSTRUCTION MANUAL

TCD210160AC

Autonics

Thank you for choosing our Autonics product.

Read and understand the instruction manual and manual thoroughly before using the product.

For your safety, read and follow the below safety considerations before using. For your safety, read and follow the considerations written in the instruction manual, other manuals and Autonics website

Keep this instruction manual in a place where you can find easily.

The specifications, dimensions, etc are subject to change without notice for product improvement Some models may be discontinued without notice. Follow Autonics website for the latest information.

## Safety Considerations

Observe all 'Safety Considerations' for safe and proper operation to avoid hazards.

A symbol indicates caution due to special circumstances in which hazards may occur.

**Warning** Failure to follow instructions may result in serious injury or death

- 01. Fail-safe device must be installed when using the unit with machinery that may cause serious injury or substantial economic loss. (e.g. nuclear power control, medical equipment, ships, vehicles, railways, aircraft, combustion apparatus, safety equipment, crime/disaster prevention devices, etc.) Failure to follow this instruction may result in personal injury, economic loss or fire.
- 02. Do not use the unit in the place where flammable/explosive/corrosive gas, high humidity, direct sunlight, radiant heat, vibration, impact or salinity may be present.

ure to follow this instruction may result in explosion or fire. 03. Install on a device panel to use.

- Failure to follow this instruction may result in fire 04. Do not connect, repair, or inspect the unit while connected to a power
- source. Failure to follow this instruction may result in fire. 05. Check 'Connections' before wiring.
- ailure to follow this instruction may result in fire. 06. Do not disassemble or modify the unit.

Failure to follow this instruction may result in fire.

**Caution** Failure to follow instructions may result in injury or product damage

01. When connecting the power input and relay output, use AWG 26 to 12 cable and connecting the sensor input and communication cable without dedicated cable, use AWG 28 to 14 cable. Failure to follow this instruction may result in fire or malfunction due to contact

02. Use the unit within the rated specifications.

Failure to follow this instruction may result in fire or product damage

- 03. Use a dry cloth to clean the unit, and do not use water or organic solvent. ailure to follow this instruction may result in fire or electric shock
- 04. Keep the product away from metal chip, dust, and wire residue which flow into the unit.

Failure to follow this instruction may result in fire or product damage.

#### **Cautions during Use**

· Follow instructions in 'Cautions during Use'. Otherwise, it may cause unexpected accidents

· Check the polarity of the terminals before wiring the temperature sensor. For RTD temperature sensor, wire it as 3-wire type, using cables in same thickness and

For thermocouple (CT) temperature sensor, use the designated compensation wire for extending wire.

- Keep away from high voltage lines or power lines to prevent inductive noise. In case of installing power line and input signal line closely, use line filter or varistor at power line and shielded wire at input signal line.
- Do not use near the equipment which generates strong magnetic force or high frequency noise
- Do not apply excessive power when connecting or disconnecting the connectors of the product.
- Install a power switch or circuit breaker in the easily accessible place for supplying or disconnecting the power
- Do not use the unit for other purpose (e.g. voltmeter, ammeter), but temperature controller
- When changing the input sensor, turn off the power first before changing. After changing the input sensor, modify the value of the corresponding parameter.

- 24 VDC --- model power supply should be insulated and limited voltage/current or Class 2, SELV power supply device.
- Do not overlapping communication line and power line.
- Use twisted pair wire for communication line and connect ferrite bead at each end of line to reduce the effect of external noise.
- · Make a required space around the unit for radiation of heat.
- For accurate temperature measurement, warm up the unit over 20 min after turning on the power.
- · Mounting multiple devices in any way other than the specified mounting method may cause heat to build up inside, which will shorten their service life. If there is a possibility of the ambient temperature rising to a temperature above the specified temperature range, take steps, such as installing fans, to cool the device. Be sure that the cooling method in not cooling just the terminal block. If only the terminal block is cooled, measurement errors may occur.
- Make sure that power supply voltage reaches to the rated voltage within 2 sec after supplying power.
- · Do not wire to terminals which are not used.
- Install DIN rail vertically from the ground.
- This unit may be used in the following environments. - Indoors (in the environment condition rated in 'Specifications') - Altitude Max. 2.000 m
- Pollution degree 2
- Installation category II

#### Ordering Information

This is only for reference, the actual product does not support all combinations. For selecting the specified model, follow the Autonics website

т м 🛈	- 22 3
<b>O channel</b> 2: 2 channels 4: 4 channels	Control output     R: Relay     S: SSR drive
<ul> <li>Alarm output</li> <li>2: Alarm output 1/2 (2 channels)</li> <li>4: Alarm output 1/2/3/4 (2 channels)</li> <li>N: None (4 channels)</li> </ul>	C: Selectable current or SSR drive output Structure B: Basic module E: Expansion module • Since the expansion module is not supplied with power/ comm. terminal. Use it with the basic module.

#### Product Components

Product  Instruction manual	-	
Side connector 1 Dower/Comm.connector 1 (only for basic modu	Product	Instruction manual
Side connector: 1     Power/comm. connector: 1 (only for basic modu	Side connector: 1	Power/Comm. connector: 1 (only for basic module)

### Sold Separately

Communication converter: SCM-Series
 Current transformer (CT)

## Manual

For proper use of the product, refer to the manuals and be sure to follow the safety considerations in the manuals

Download the manuals from the Autonics website.

# Software

Download the installation file and the manuals from the Autonics website.

#### DAQMaster

DAQMaster is comprehensive device management program. It is available for parameter setting, monitoring.

#### Dimensions

• Unit: mm, For the detailed drawings, follow the Autonics website.



#### Specifications

Series		TM2 TM4						
No. of cha	nnels	2 channels 4 channels						
Power sup	oply	24 VDC== ±10%						
Allowable range	voltage	90 to 110% of rated voltage						
Power cor	sumption	≤ 5 W (for Max. load)						
Sampling	period	50 ms (2 channels synchronous sampling)	100 ms (4 channels synchronous sampling)					
Input spec	cification	Refer to 'Input Type and Using Range'.						
	CT input	O.0-50.0 A (primary current measurement range)     OT ratio: 1/1,000     Measurement accuracy: ±5% F.S. ±1 digit	-					
Option input	Digital input	• Contact ON: ≤ 1 kΩ, OFF: ≥ 100 kΩ • Non contact residual voltage: ≤ 1.5 VDC== leakage current: ≤ 0.1 mA • Outflow current: ≈ 0.5 mA per input	-					
	Relay	250 VAC~ 3 A 1a, 30 VDC= 3 A 1a						
Control	SSR	12 VDC== ±3 V, ≤ 30 mA	22 VDC== $\pm$ 3 V, $\leq$ 30 mA					
output	Current	DC 4 - 20 mA or DC 0 - 20 mA (Load resistance: $\leq$ 500 $\Omega$ )						
Alarm out	put	250 VAC~ 3 A 1a	-					
RS485 Cor	nm.	Modbus RTU						
Display ty	pe	None- parameter setting and monitoring is available at external devices						
Control type	Heating, Cooling Heating & Cooling	ON/OFF, P, PI, PD, PID Control						
Hysteresis	5	1 to 100 (0.1 to 100) °C/°F						
Proportio	nal band (P)	0.1 to 999.9 °C/°F						
Integral ti	me (I)	0 to 9.999 sec						
Derivative	time (D)	0 to 9,999 sec						
Control cv	cle (T)	0.1 to 120.0 sec						
Manual re	set	0.0 to 100.0 %						
Relav life	Mechanical	≥ 10,000,000 operations						
cycle	Electrical	$\geq$ 100,000 operations (250 VAC $\sim$ 3 A load resistance)						
Dielectric	strength	Between input terminal and power terminal: 2,000 VAC $\sim$ 50/60 Hz for 1 min						
Vibration		0.75 mm amplitude at frequency of 5 to 55 Hz (for 1 min) in each X, Y, Z direction for 2 hours						
Insulation	resistance	100 MΩ (500 VDC megger)						
Noise imn	nunity	$\pm$ 0.5 kV square shaped noise (pulse width 1 µs) by noise simulator						
Ambient t	emperature	-10 to 50 °C, storage: -20 to 60 °C (no freezing or condensation)						
Ambient h	numidity	35 to 85%RH, storage: 35 to 85%RH (no freezing or condensation)						
Channel in	nsulation	Dielectric strength 1,000 VAC~						
Insulation	type	Double insulation or reinforced insulation (mark: , dielectric strength between the measuring input part and the power part: 1 kV)						
Approval		C E e SALus 🕼 EHE						
Unit weig (packaged	ht i)	Basic module: ≈ 152 g (≈ 217 g)     Expansion module: ≈ 143 g (≈ 208 g)						

# Input Type and Using Range

The setting range of some parameters is limited when using the decimal point display.

Input type		Decimal Display point method		Using range (°C)			Using range (°F)			
	K (CA)	1	K (CA) .H	-200	to	1,350	-328	to	2,462	
	R (CA)	0.1	K (CA) .L	-200.0	to	1,350.0	-328.0	to	2462.0	
	1/10)	1	J (IC) .H	-200	to	800	-328	to	1,472	
	J (IC)	0.1	J (IC) .L	-200.0	to	800.0	-328.0	to	1472.0	
	E (CD)	1	E (CR) .H	-200	to	800	-328	to	1,472	
	L (CR)	0.1	E (CR) .L	-200.0	to	800.0	-328.0	to	1,472.0	
	T (CC)	1	T (CC) .H	-200	to	400	-328	to	752	
	1 (CC)	0.1	T (CC) .L	-200.0	to	400.0	-328.0	to	752.0	
Th	B (PR)	1	B (PR)	0	to	1,800	32	to	3,272	
couplo	R (PR)	1	R (PR)	0	to	1,750	32	to	3,182	
-coupie	S (PR)	1	S (PR)	0	to	1,750	32	to	3,182	
	N (NN)	1	N (NN)	-200	to	1,300	-328	to	2,372	
	C (TT) 01)	1	C (TT)	0	to	2,300	32	to	4,172	
	G (TT) 02)	1	G (TT)	0	to	2,300	32	to	4,172	
	L (IC)	1	L (IC) .H	-200	to	900	-328	to	1,652	
		0.1	L (IC) .L	-200.0	to	900.0	-328.0	to	1,652.0	
	11/00)	1	U (CC) .H	-200	to	400	-328	to	752	
	0(00)	0.1	U (CC) .L	-200.0	to	400.0	-328.0	to	752.0	
	Platinel II	1	PLII	0	to	1,400	32	to	2,552	
	JPt100 Ω	1	JPt100.H	-200	to	650	-328	to	1,202	
DID	JPt100 Ω	0.1	JPt100.L	-200.0	to	650.0	-328.0	to	1,202.0	
NID	DPt100 Ω	1	DPt100.H	-200	to	650	-328	to	1,202	
	DPt100 Ω	0.1	DPt100.L	-200.0	to	650.0	-328.0	to	1,202.0	

01) C (TT): Same as existing W5 (TT) type sensor 02) G (TT): Same as existing W (TT) type sensor

#### Measurement accuracy

Input type Using temperature Measurement accuracy					
Thermo -couple	At room temperature (23 ±5 °C)	(PV ±0.5% or ±1 °C higher one) ±1-digit • Thermocouple K, J, T, N, E below -100 °C and L, U, PLII: ±2 °C ±1-digit • Thermocouple C, G and R, S below 200 °C: ±3 °C ±1-digit • Thermocouple B below 400°C: there is no accuracy standards			
RTD	Out of room temperature range	$\begin{array}{l} (PV \pm 0.5\% \ or \pm 2\ ^\circ C \ higher \ one) \pm 1\ digit \\ \bullet RTD \ Cu50\ \Omega, \ DPt50\ \Omega; \ (PV \pm 0.5\% \ or \pm 3\ ^\circ C \ higher \ one) \pm 1\ digit \\ \bullet Thermocouple \ R, \ S, \ B, \ C, \ G, \ L, \ U: \ (PV \pm 0.5\% \ or \pm 5\ ^\circ C \ higher \ one) \\ \pm 1\ digit \\ \bullet Thermocouple \ below \ -100\ ^\circ C: \pm 5\ ^\circ C \end{array}$			

# Communication Interface

#### **RS485**

Protocol	Modbus RTU				
Application standard	EIA RS485 compliance with				
Maximum connection	31 units (address: 01to31)				
Synchronization type	Asynchronous				
Connection type	vo-wire half duplex				
Comm. effective range	≤ 800 m				
Comm. speed	2,400 / 4,800 / 9,600 (default) / 19,200 / 38,400 (parameter)				
Start bit	1 bit (fixed)				
Data bit	8 bit (fixed)				
Parity bit	None (default) , Odd, Even				
Stop bit	1 bit, 2 bit (default)				

When changing the setting value related to communication interface, reboot the device for normal operation.
 It is not allowed to set overlapping communication address at the same communication line.

 It is recommended to use Autor ommunication converter. Please use twisted pair wire, which is suitable for RS485 communicatio

#### Address

Set the communication address with the communication address setting switch (SW1, default: 1) and communication address group switch (SW2, default: +0). • When setting as 0 it does not a

SW1																
SW2	0	1	2	3	4	5	6	7	8	9	Α	В	С	D	E	F
+0 +16	X	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15
+0+16	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31

#### Connections



TM4



#### **Crimp Terminal Specifications**

• Unit: mm, Use the crimp terminal of follow shape

Wire ferrule



# Installation Method

#### Connection between modules



- 1. Remove END cover (1) of each module (except END cover of the first and last module).
- 2. Insert side connector (2) and connect them tightly to ③ direction (max 30 units)
- 3. Press lock switch (④) to lock direction.
- Supply adequate power for power input specifications and overall capacity. (Max. power when connecting 31 modules: 31 units×5 W=155 W)

#### Mounting with bolts



1. Pull the rail lock at the top and bottom of the module to 1direction.

- Separatior

2. Insert M4 bolts to ② direction and fix it on rail lock. (Tightening torque: 0.5 to 0.9 N m)

#### Mounting on DIN rail

## - Installation



1. Hang the top rail lock to DIN rail. 2. Push to ① direction and press to (2) direction

# 0=0

1. Press the module to ① direction. . Keep it pressed and pull it to 2 direction

input

Power / C Connecto

[Basic module]

Precautions

# Install the module vertically

• Use end plates (sold separately, not available from Autonics) to fix firmly

# Indicator

Errors

Name	Status	Color	Description	Troubleshooting
PWR	ON	Red	□ channel error: Input < Input range,	When the error factor is
CH□	Flash	Red	open or not connected	returns to normal operation.

01) Cvcle: 0.5 sec

#### Communication output, DAQMaster

Communication output (decimal) DAQMaster		Description	Troubleshooting		
'31000'	Display 'OPEN'	Input sensor is open or not connected	When the error factor is		
'30000'	Display 'HHHH'	Input > Input range	resolved, it automatically		
'-30000'	Display 'LLLL'	Input < Input range	returns to normal operation.		